

Clarkdale Fire District

(928) 639-4591
(928) 649-2655 fax

PO Box 1236
Clarkdale, AZ 86324

Press Release

Contact: **Joe Moore, Fire Chief**
Phone: **(928) 639-4591**

FOR IMMEDIATE RELEASE

Date: 8/24/2010

Incident Address: **500 Luke Lane**

Incident Commander (name & title): **Joe Moore, Fire Chief**

Incident Date:	8/24/10	Incident Time:	07:41	First In Engine:	E211
Type of Structure:	Haz Mat	# Units of Scene:	13	# Fire Units on Scene:	11
Total # Firefighters:	23	# Assisting Agencies:	5	# Ambulances:	2
Time to Control Incident:	1Hr 54Min	Total Incident Duration:	2Hr 25Min		
Value of Structure:	\$0.00	Value of Equip/Vehicles:	\$0.00	Value of Contents:	NA
\$ Loss of Structure:	\$0.00	\$ Loss of Equip/Vehicles:	\$0.00	\$ Loss of Contents:	NA

# Displaced Occupants:	0	# Adults injured:	0	# Minors Injured:	0
# Civilian Fatalities:	0	# Civilians Rescued/Saved:	0	# FF Injuries:	0

Incident Description

At 07:41 am we received a call from Clarkdale Minerals regarding a 150 pound chlorine cylinder leaking. They were not able to secure the leak due to a malfunctioning valve. When E211 arrived on scene all personnel had been evacuated. The leaking cylinder was contained in a laboratory. The leak was minor but rendered the building unsafe to occupy. Upon the arrival of the Camp Verde Fire District Hazmat team, we assisted with preparing them to enter the building. Once inside the building it took 12 minutes for the team to secure the leak. Verde Valley Ambulance Company provided medical and rehabilitation. Cottonwood Fire Department provided decontamination. Jerome Fire Department provided for the safety and accountability of the crews. All the agencies did a outstanding job working together on this incident.

END

Continued to Next Page